



8431 Murphy Drive  
Middleton, WI 53562 USA

Telephone: 608.836.4400  
Facsimile: 608.831.9279  
www.intertek.com

# Test Verification of Conformity

**In the basis of the tests undertaken, the sample(s) of the below product have been found to comply with the requirements of the referenced specifications at the time the tests were carried out.**

<b>Applicant Name &amp; Address:</b>	Roof Tech Inc. 92 Hamilton Drive Novato, CA 94949 USA
<b>Product Description:</b>	Photovoltaic Mount
<b>Ratings &amp; Principle Characteristics:</b>	<u>Fire Class Resistance Rating:</u> -Flush Mount (Symmetrical). Class A Fire Rated for Steep Slope applications when using Type 1 listed photovoltaic modules. Both products tested with a 5" gap (distance between the bottom the module frame and the roof covering), per the standard this system can be installed at any gap allowed by the manufacturers installation instructions. No perimeter guarding is required.
<b>Models:</b>	RT-E and RT-E Air Mount
<b>Brand Name:</b>	Roof Tech
<b>Relevant Standards:</b>	UL 2703 (Section 15.2 and 15.3) Standard for Safety Mounting Systems, Mounting Devices, Clamping/Retention Devices, and Ground Lugs for Use with Flat-Plate Photovoltaic Modules and Panels, First Edition dated Jan. 28, 2015 <b>Referencing</b> UL1703 Third Edition dated Nov. 18, 2014, (Section 31.2) Standard for Safety for Flat-Plate Photovoltaic Modules and Panels.
<b>Verification Issuing Office:</b>	Intertek Testing Services NA, Inc. 8431 Murphy Drive Middleton, WI 53562
<b>Date of Tests:</b>	11/13/2014 to 03/9/2015
<b>Test Report Number(s):</b>	1011824896MID-001r1 and 101824896MID-003r1.

**This verification is part of the full test report(s) and should be read in conjunction with them. This report does not automatically imply product certification.**

**Completed by:** Chad Naggs  
**Title:** Technician II, Fire Resistance

**Signature:**  
**Date:** 03/23/2015

**Reviewed by:** Gregory Allen  
**Title:** Engineering Team Lead, Fire Resistance

**Signature:**  
**Date:** 03/23/2015

*This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.*